

## Classification Report

Number	19-004153-PR01 (NW-A01-0203-en-02)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Lift-sliding door, scheme D
Designation	System: E50 EVO Shipping name: E50 EVO
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium profiles with thermal break; Type of opening Lifting sliding; Opening direction Sash right before sash left; Overall dimensions (W x H) 3597 mm x 2393 mm
Special features	Test sequence. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drai- nage.

## Result

Air permeability according to EN 12207:2016-12

**Class: 4**

Resistance to wind load according to EN 12210:2016-03

**Class: C1/B2**

Watertightness according to EN 12208:1999-11

**Class: 8A**

ift Rosenheim

19.05.2020



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing

## Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 19-004153-PR01 PB-  
A01-0203-en-01

## Representation



## Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

## Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

## Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: AC8-AC199