






Classification Report

| | |
|------------------|---|
| Number | 20-000966-PR03 (NW-A01-0203-en-03) |
| Owner | ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece |
| Product | Side hung window (ventilation vent) |
| Designation | System: E68 Shipping name: E68 |
| Details | Manufacturer ETEM BULGARIA S.A, - Sofia; Material Aluminium; Type of opening Turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 316 mm x 2090 mm |
| Special features | Material compatibility must be taken into account. Material durability must be taken into account. |

Result

| | | | | |
|---|---|---|---|--|
| Air permeability according to EN 12207:2016-12 | Resistance to wind load according to EN 12210:2016-03 | Watertightness according to EN 12208:1999-11 | Operating forces according to EN 13115:2001-07 | Mechanical properties according to EN 13115:2001-07 |
|  |  |  |  |  |
| 4 | C4/B4 | 9A | 1 | 4 |

Basis *)

EN 14351-1:2006+A2:2016-09 *) and corresponding national versions (e.g. DIN EN)
Test report: 20-000966-PR03 PB-A01-0203-en-02
Replaces ift-Nachweis: 20-000966-PR03 NW-A01-0203-en-02 dated 05.06.2020.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check




www.ift-rosenheim.de/ift-geprueft
ID: 7E2-61623

ift Rosenheim
09.06.2020



Michael Breckl-Stock
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing