







Number	21-001428-PR01 (NW-A01-020305-en-01)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Double tilt and turn casement door with central opening meeting stile
Designation	System: EW70 Shipping name: EW70 Double Casement Tilt & Turn Window
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to inside, Inac- tive casement DIN left (opening) to inside; Overall dimensions (W x H) 1717 mm x 2200 mm
Special features	Test sequence. Position of locking. Material compatibility must be taken into account. Material durability must be taken into account.

Result **)

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Operating forces according to EN 13115:2001-07	Mechanical properties according to EN 13115:2001-07	Impact resistance according to EN 13049:2003-04
					
4	C3/B3	E750	1	2	4

ift Rosenheim
08.06.2021



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-001428-PR01 PB-
A01-020305-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

**) Decision rule: For the conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: D8E-B9D08