

Number	21-004640-PR02 (NW-A01-02-en-01)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Top hung pivoting window
Designation	System: EF50 Shipping name: Curtain wall Structural Glazing projected window
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Top-hung window; Opening direction Outwards; Overall dimensions (W x H) 1160 mm x 1410 mm
Special features	Test sequence. Position of locking. Increased operating forces. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

Result **)

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: CE2200/BE2200

Watertightness according to EN 12208:1999-11



Class: E1950

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

27.01.2022



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-004640-PR02 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 796-02324